



工程设计资质证书编号  
建筑甲级:A113007169  
园林甲级:A113007169  
规划乙级:城规142010  
市政乙级:A213007166  
人防乙级:A213007166

中盛弘宇建设科技有限公司  
Zhongsheng Hongyu Construction Technology Co., Ltd.

备注 NOTE  
\*本图经施工图审查机构及消防审批部门审查合格方可用于施工。  
版权所有中盛弘宇建设科技有限公司所有，未经许可，不得擅  
自使用，更改和复制等其它用途。  
This drawing can only be used for construction after being  
examined to be qualified and approved by Drawing Appraisal  
Unit & Fire Control Committee. The copyright belongs to th  
e Zhongsheng Hongyu Construction Technology Co., Ltd. Without  
written permission, it's prohibited to use, change or copy  
the drawing for other purposes.

合作设计单位 CO-OPERATED WITH

说明 EXPLAIN

审定 APPROVED BY	支永涛	支永涛
审核 VERIFIED BY	李亮	
项目负责人 PROJECT CHIEF	宋志荣	宋志荣
专业负责人 PROFESSION CHIEF	支永涛	支永涛
校对 CHECKED BY	周兴	周兴
设计 DESIGNED BY	周浪	周浪

建设单位 CONSTRUCTION

重庆华牧现代农业有限公司

工程名称 PROJECT

华牧现代农业生态循环智能化康鸡项目配电工程

项目名称 SUB PROJECT

图纸名称 DRAWING TITLE

1600kVA箱变低压进线柜二次接线及端子排图

工程编号

图号 NO.

阶段  
STAGE

施工图  
CONSTRUCTION

专业  
SPECIALTY

电气  
ELECTRIC

比例  
SCALE

1:1  
DRAWING






日期  
DATE

2023.04


版本号  
VERSION NUMBER

A


签字齐全 盖章有效



控制电源	断路器控制回路
合闸回路	
分闸回路	
储能回路	
储能指示	
分闸指示	
合闸指示	处理单元
故障指示	



控制电源	各室照明回路
熔断器	
变压器室	
高压室	
低压室	温控电源
温控电源	



控制电源	变压器室风机散热回路
熔断器	
温控回路	
温控器	
传感器 装变压器室	变压器风机回路
变压器风机回路	

